GOVERNMENT OF ANDHRA PRADESH
ABSTRACT

Water Resources Department- Permission to allocate and draw 0.300 TMC water from Kandaleru Reservoir towards Puttur drinking water supply improvement Scheme taken under AIIB for drinking water through combined OT Sluice @ Km. 88.940 of SSG canal on the TGP Main canal instead of @ Km. 89.225 on S.S.G. canal- Amendment - Orders- issued.

WATER RESOURCES (WRG-GRC) DEPARTMENT

G.O.RT.No. 173 Dated: 31-05-2021.

Read the followings:-

1) G.O. Rt. No. 302, Water Resources (WRG-GRC) Department, Dated: 24.06.2019.
2) From the Engineer-in-Chief (Irr), Water Resources Department, Vijayawada, Lr.No:ENC(I)/EE/DEE1/AEE2/IWS(CMP-Industrial Park, Kosalanagaram), dated 15.10.2020 and dated:06.04.2021

@@@

In the G.O.1st read above, orders were issued and permission to allocate and draw 0.300 TMC water from Kandaleru Reservoir towards Puttur drinking water supply improvement Scheme taken under AIIB for drinking along with construction of Off Take sluice on the TGP main canal i.e., at K.M 89.225 on S.S.G. canal.

2. In the circumstances reported by the Engineer-in-Chief (Irr), Vijayawada in his letter 2nd read above duly enclosed the detailed proposals of the Chief Engineer, NTR TGP and requested the Government to amend the **G.O.Rt.No. 302, WR (WRG-GRC) Dept., dated 24.06.2019** by changing the location of OT Sluice @ Km 89.225 on SSG Canal for drawl of water to Puttur drinking water supply scheme to the new location of combined OT Sluice @ Km 88.940 of SSG Canal which falls towards drawing water to Puttur drinking water supply Scheme, Industrial Park, Kosalanagaram and Industrial Park, Nindra, Chittoor district and also for M/s Hindustan Coca-Cola Beverage Pvt. Ltd., Srikalahasti subject to certain conditions.

3. Government after careful examination of the proposals of the Engineer-in-Chief (Irr), Water Resources Department, Vijayawada and hereby agreed to amend the **G.O.Rt.No. 302, WR (WRG-GRC) Department dated 24.06.2019** by changing the location of Off-take Sluice @ Km 88.940 of SSG Canal instead of @ Km 89.225 on SSG Canal for drawl of water to Puttur drinking water supply scheme and also allocation of water to the Industrial parks with the following conditions;-

1. The water shall be utilized for the purpose for which it is allotted within three years of the orders or till the completion of construction of pipe line network from Kandaleru reservoir by the APIIC Ltd., for drawl of 4.55 TMC of water whichever is earlier.

2. The release of water to a tune of 0.30 TMC subjected to acquire of the entire land both in IP, Kosalanagaram and IP, Nindra of Chittoor district to an extent of 3500 acres.
3. The firm can draw water only on prorata basis during the period of flows in the canal.
4. The firm cannot claim the permission as a right at the cost of irrigation.
5. The cost of construction of pipe line and other infrastructure should be borne by the firm duly acquiring the necessary land etc., at their own cost.
6. The water rates payable shall be as levied by the Government as per the norm of Industrial usage supply from time to time.
7. A detailed plan showing the location of intake arrangements, pump house, alignment of pipe line and conveyance system should be furnished to the department for approval.
8. Pump house should be constructed away from the Channel bund duly considering G.O.Ms.No. 119, dated 28.03.2017.
9. Off Take Sluice should be constructed as per the norms of Water Resources Department and banks should be protected with wing walls and banks should be constructed with proper consolidation under the supervision of the Departmental Officers.
10. Water measuring devices should be placed at the off take point and proper locking arraignments and shuttering arrangements must be made with their own cost under the supervision of the Water Resources Department.
11. Digital Water meters and measuring devices should be installed at the pump house by the industry at their own cost to measure the water consumed and should be made available to the Water Resources and Revenue Departments authorities all times for inspection.
12. The operation of Off-Take Sluice shall be under the control of Water Resources Department only.
13. Water supply will be stopped when there is lean flows in the channel.
14. The water charges are to be paid in advance for the year on Demand as per the rate fixed by the Government.
15. The firm should be given an undertaking that they will not raise any legal Complications for not supplying of water during the drought period, short fall rains and any type of unforeseen problems.
16. The firm should make its own arrangements for sufficient storage of water during non supply period.
17. The Water Resources Department is no way responsible for non supply of water due to any reasons.
18. The Department is no way responsible for any damages that may occur to the off take house during floods.
19. The Department is no way responsible for any dispute that arises with neighboring industries and public and any legal matters.
20. The firm should not create any objection for improvement / Modernization works to the said Reservoir in future and they have to relocate the pumps if necessary, with their own cost.
21. The Water Resources Department reserves the right for cancelation of the permission without assigning any reason thereof.

22. The beneficiary is to abide by any other condition laid down by the Water Resources Department from time to time.
23. Violation of any of the conditions mentioned above shall entitle cancellation of permission granted for drawl of water without any notice.
24. If construction of OT Sluice is in the reach of full embankment due care shall be taken by the construction department to ensure safety of the entire system as the region is a drought prone area.

4. The Engineer-in-Chief (Irr), Water Resources Department, Vijayawada shall take necessary action accordingly.

J. SYAMALA RAO
SECRETARY TO GOVERNMENT

To
The Engineer-in-Chief (Irr), Water Resources Department, Vijayawada.
Copyto:
The Chief Engineer, NTR Telugu Ganga Project, Tirupati.
The P.S to Hon'ble Minister for Water Resources Department.
The P.S to Secretary to Government, Water Resources Department.
S.F/S.C.

/FORWARDED :: BY ORDER//

SECTION OFFICER